

Температурный график котельной 95-70 °С при  $t_{нр}=-32$  °С и  $t_{вр}=+20$  °С

$t_{н}$	без ГВС		с ГВС		
	$t_1$	$t_2$	$t_1$	$t_2$	$\Delta t$
10	39.1	34.3	70.0	60.1	9.9
9	40.7	35.4	70.0	59.8	10.2
8	42.2	36.5	70.0	59.5	10.5
7	43.7	37.5	70.0	59.3	10.7
6	45.2	38.5	70.0	59.0	11
5	46.7	39.5	70.0	58.8	11.2
4	48.2	40.5	70.0	58.5	11.5
3	49.6	41.5	70.0	58.3	11.7
2	51.1	42.4	70.0	58.0	12
1	52.5	43.4	70.0	57.8	12.2
0	53.9	44.3	70.0	57.5	12.5
-1	55.3	45.2	70.0	57.3	12.7
-2	56.7	46.1	70.0	57.0	13
-3	58.1	47.0	70.0	56.8	13.2
-4	59.4	47.9	70.0	56.5	13.5
-5	60.8	48.8	70.0	56.3	13.7
-6	62.1	49.6	70.0	56.1	13.9
-7	63.5	50.5	70.0	55.8	14.2
-8	64.8	51.4	70.0	55.6	14.4
-9	66.1	52.2	70.0	55.3	14.7
-10	67.5	53.0	70.0	55.1	14.9
-11	68.8	53.9	70.0	54.9	15.1
-12	70.1	54.7	70.1	54.7	15.4
-13	71.4	55.5	71.4	55.5	15.9
-14	72.7	56.3	72.7	56.3	16.4
-15	73.9	57.1	73.9	57.1	16.8
-16	75.2	57.9	75.2	57.9	17.3
-17	76.5	58.7	76.5	58.7	17.8
-18	77.8	59.5	77.8	59.5	18.3
-19	79.0	60.3	79.0	60.3	18.7
-20	80.3	61.1	80.3	61.1	19.2
-21	81.5	61.8	81.5	61.8	19.7
-22	82.8	62.6	82.8	62.6	20.2
-23	84.0	63.3	84.0	63.3	20.7
-24	85.3	64.1	85.3	64.1	21.2
-25	86.5	64.9	86.5	64.9	21.6
-26	87.7	65.6	87.7	65.6	22.1
-27	88.9	66.3	88.9	66.3	22.6
-28	90.2	67.1	90.2	67.1	23.1
-29	91.4	67.8	91.4	67.8	23.6
-30	92.6	68.6	92.6	68.6	24
-31	93.8	69.3	93.8	69.3	24.5
-32	95.0	70.0	95.0	70.0	25

Энергоснабжающая организация

М.П.

Потребитель

М.П.

